



**TAMILNADU FIRE AND RESCUE SERVICE DEPARTMENT
FIRE AND RESCUE STATION - KUMARAPALAYAM**

S.No : 12/2026

Date: 07.05.2026

R.C.No : 289/IV/2026

No objection Certificate

Sub: Tamil Nadu Fire & Rescue Services – Namakkal District – Use of Places and trade for purpose involving risk from fire – No objection Certificate – Issued.

Ref: 1.Govt G.O. No:122 school Education (2) Department, Dated: 14.09.2004
2.Govt G.O. No:123 school Education (2) Department, Dated: 14.09.2004
3.Application from The Principal, Royal International School Senior Secondary (CBSE), Dated : 06.05.2026


With reference to the letter cited above, Premises **M/S. Royal International School Senior Secondary (CBSE) S.F.No.355**, Manjupalayam Road, Nehru Nagar Bus Stop, NH-544 Salem Bypass Road, Pallakkapalayam, Kumarapalayam Taluk, Namakkal District was inspected by Mr.R.Sengottuvelu, Station Fire Officer on 07.05.2026. There is no objection from the Fire Service Point of view to license such below conditions as may be Prescribed. This license is valid for **THREE YEARS** from 07.05.2026 to 06.05.2029 and Should be renewed on 07.05.2029.

CONDITIONS

1. All firefighting equipment should always be kept in good working condition at all times and it should be as per the NBC 2016 part -IV maintained well and working in good condition. The trained personnel should always be available to operate the systems in case of any emergency.
2. Fire extinguishers should be installed and maintained as per IS 2190:2010
3. Mock drill should be periodically conducted.
4. Any addition and/or alteration of a permanent or temporary structure should be intimated to the Fire and Rescue Services Department.
5. Fire order / contingency plan / evacuation plan should be prepared and displayed in each floor at prominent places and Do's &Don'ts boards should be displayed.
6. Emergency fire exit, staircases and doors should not be obstructed.
7. Good housekeeping should be maintained and dumping of waste materials anywhere should be avoided.
8. All the electrical equipment, fitting, accessories and Wiring system should be maintained. As per IS 1646: 1997 Code of Practice for Fire Safety of Building (General) Electrical Installation should be followed.

OFFICE SEAL




Station Officer
Fire and Rescue Station
Kumarapalayam

To,
The Principal,
Royal International School Senior Secondary (CBSE),
Manjupalayam Road, Pallakkapalayam,
Kumarapalayam Taluk, Namakkal District.

Copy: District officer, Fire and Rescue Service, Namakkal District